


C/17

No. ED/EE/T-33/2013-2014/ 997  
Administration of Daman & Diu (UT)  
O/o the Executive Engineer,  
Electricity Department, Pl.No.35,  
OIDC Corporate Office, Nr. Fire Station  
Somnath, Daman : 396 210.  
Tele Fax. No. (0260) 2254745  
Web: [www.dded.gov.in](http://www.dded.gov.in)  
E Mail:- [eddamandiu@gmail.com](mailto:eddamandiu@gmail.com)  
Dated: 24 /06/2013

**CORRIGENDUM NO-01 IN TENDER NOTICE NO.03 OF THE YEAR 2013-2014**

**1) For TS-12**

Sr.No	Existing Particular in RMU Specification	Should be read as Particular in RMU Specification
4.17	Auxiliaries:- The switchgear should be provided with motor operation, auxiliary contacts and short-circuit indicators. Necessary provision shall be made in separate enclosure for mounting RTUs, Terminal Blocks and Battery backup. Suitable 24VDC battery backup arrangement shall be provided by manufacturer for operation of motor and functioning of RTU. Upkeep and maintenance of batteries shall be done by user. However, manufacturer shall share the necessary steps that can be taken to ensure longevity in life of batteries. Incorporation of RTU/batteries within the RMU enclosure is not recommended, as it may cause maloperation due to vibrations of operation, and weakening of signal strength.	Auxiliaries:- The Switchgear should be Manually operated

  
Executive Engineer  
Electricity Department  
Daman