

## SCHEDULE – II


### 8. Overall Standard of Performance

Reliability Indices of Daman and Diu :

Month	SAIFI	SAIDI for 11 KV Feeder	RI of 11 KV feeder	SAIDI for Consumers	RI for Consumers
January-16	5.70	711.79	98.41	150.94	99.66
February-16	3.82	368.48	99.12	205.95	99.51
March-16	4.00	179.99	99.60	102.86	99.77

### 4<sup>th</sup> Quarter Reliability Indices for the year 2015-16:

Month	SAIFI	SAIDI for 11 KV Feeder	RI of 11 KV feeder	SAIDI for Consumers	RI for Consumers
January-16 to March-16	13.51	1259.26	99.04	459.76	99.65

  
Executive Engineer (Elect.)  
Electricity Department,  
Daman