

ED/EE/T-33/2019-2020/54
Office of the Executive Engineer,
Electricity Department,
VIDYUT BHAVAN,
Somnath-Kachigam Road ,
Daman:-396210
Web:- www.dded.gov.in
Email:- elec-dmn-dd@nic.in
Date:- 07/04/2020

CORRIGENDUM NO-01 IN TENDER NOTICE NO.20 OF THE YEAR 2019-2020 FOR TENDER ID- 400120.

Change of Bidding Date:-

Bid document down loading end date is 27/05/2020 up to 10.00 Hrs. instead of 21/04/2020 and last date & time for receipt of bid is 27/05/2020 up to 12.00 Hrs. instead of 21/04/2020.

Date of opening of Technical stage is 28/05/2020 at 12.00 Hrs. instead of 22/04/2020 and opening of price bids is 29/05/2020 at 10.00 Hrs. instead of 24/04/2020.

For :-

19 SCOPE OF WORK:

1. Supply of **Sudhire make** 250KVA Silent DG Set Comprising of Cummins make Engine Model 6L8.0 AA G-4 Coupled to 415 Volts 250KVA, 3 Phase, Stamford make Alternator mounted on a common base frame along with other Accessories I.E Control Panel , Fuel Tank, Battery with leads . with 2 years warranty as per specification (Annexure A)

After Sr No. 36 of Terms and Condition:-

Name of Work :- . Supply, Erection, Testing and Commissioning of New DG Set of 250KVA with AMF Panel at Govt. House, Fort Area Moti Daman.(2nd Call) & BOQ

Sr. No.	Description	Qty	Unit	Rate	Total Cost
1	Supply of Sudhire make 250KVA Silent DG Set Comprising of Cummins make Engine Model 6L8.0 AA G-4 Coupled to 415 Volts 250KVA, 3 Phase, Stamford make Alternator mounted on a common base frame along with other Accessories I.E Control Panel , Fuel Tank, Battery with leads . with 2 years warranty as per specification (Annexure A)	1	Nos.		

Read As :-


19 SCOPE OF WORK:

1. Supply of 250KVA Silent DG Set Comprising of Cummins make Engine Model 6L8.0 AA G-4 Coupled to 415 Volts 250KVA, 3 Phase, Stamford make Alternator mounted on a common base frame along with other Accessories I.E Control Panel , Fuel Tank, Battery with leads . with 2 years warranty as per specification (Annexure A)

After Sr No. 36 of Terms and Condition:-

Name of Work :- . Supply, Erection, Testing and Commissioning of New DG Set of 250KVA with AMF Panel at Govt. House, Fort Area Moti Daman.(2nd Call) & BOQ

Sr. No.	Description	Qty	Unit	Rate	Total Cost
1	Supply of 250KVA Silent DG Set Comprising of Cummins make Engine Model 6L8.0 AA G-4 Coupled to 415 Volts 250KVA, 3 Phase, Stamford make Alternator mounted on a common base frame along with other Accessories I.E Control Panel , Fuel Tank, Battery with leads . with 2 years warranty as per specification (Annexure A)	1	Nos.		


Executive Engineer (Elect)
Daman